



SECTION 08 36 00
SECTIONAL OVERHEAD DOORS
521S SERIES ALUMINUM SECTIONAL OVERHEAD DOORS

Display hidden notes to specifier by using 'Tools'/'Options'/'View'/'Hidden Text'. On newer versions of Microsoft Word click on round Windows logo in top left corner, Click on 'Word Options' button at bottom of drop down menu. Click on 'Display' on left menu bar, and check the box for 'Hidden Text'.

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Glazed Aluminum Sectional Overhead Doors
- B. Electric Operators and Controls.
- C. Operating Hardware, tracks, and support.

1.2 RELATED SECTIONS

- A. Section 03300 - Cast-In-Place Concrete: Prepared opening in concrete. Execution requirements for placement of anchors in concrete wall construction.
- B. Section 04810 - Unit Masonry Assemblies: Prepared opening in masonry. Execution requirements for placement of anchors in masonry wall construction.
- C. Section 05500 - Metal Fabrications: Steel frame and supports.
- D. Section 06114 - Wood Blocking and Curbing: Rough wood framing and blocking for door opening.
- E. Section 07900 - Joint Sealers: Perimeter sealant and backup materials.
- F. Section 08710 - Door Hardware: Cylinder locks.
- G. Section 09900 - Paints and Coatings: Field painting.
- H. Section 11150 – Parking Control Equipment: Remote door control.
- I. Section 16130 - Raceway and Boxes: Empty conduit from control station to door operator.
- J. Section 16150 - Wiring Connections: Electrical service to door operator.

1.3 REFERENCES

- A. [ANSI/DASMA 102](#) - American National Standard Specifications for Sectional Overhead Type Doors.

1.4 DESIGN / PERFORMANCE REQUIREMENTS

- A. Wind Loads: Design and size components to withstand loads caused by pressure and suction of wind acting normal to plane of wall as calculated in accordance with applicable code.

1. Design pressure of _____ lb/sq ft (_____ kPa).

B. Wiring Connections: Requirements for electrical characteristics.

1. 208 volts, single phase, 60 Hz (190-207V range)
2. 208 volts, three phase, 60 Hz (190-207V range)
3. 230 volts, single phase, 60 Hz (208-245V range)
4. 230 volts, three phase, 60 Hz (208-245V range)
5. 460 volts, three phase, 60 Hz (456-495V range)
6. 575 volts, three phase, 60 Hz (517-632V range)

C. Single-Source Responsibility: Provide doors, tracks, motors, and accessories from one manufacturer for each type of door. Provide secondary components from source acceptable to manufacturer of primary components.

1.5 SUBMITTALS

A. Submit under provisions of Section 01300.

B. Product Data: Manufacturer's data sheets on each product to be used, including:

1. Preparation instructions and recommendations.
2. Storage and handling requirements and recommendations.
3. Installation methods.

C. Shop Drawings: Indicate plans and elevations including opening dimensions and required tolerances, connection details, anchorage spacing, hardware locations, and installation details.

D. Manufacturer's Certificates: Certify products meet or exceed specified requirements.

E. Operation and Maintenance Data.

1.6 QUALITY ASSURANCE

A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum five years documented experience.

B. Installer Qualifications: Authorized representative of the manufacturer with minimum five years documented experience.

C. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories, Inc. acceptable to authority having jurisdiction as suitable for purpose specified.

1.7 DELIVERY, STORAGE, AND HANDLING

A. Store products in manufacturer's unopened labeled packaging until ready for installation.

B. Protect materials from exposure to moisture until ready for installation.

C. Store materials in a dry, ventilated weathertight location.

1.8 PROJECT CONDITIONS

A. Pre-Installation Conference: Convene a pre-installation conference just prior to commencement of field operations, to establish procedures to maintain optimum working conditions and to coordinate this work with related and adjacent work.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Overhead Door Corp., 2501 S. State Hwy. 121, Suite 200, Lewisville, TX 75067. ASD. Tel. Toll Free: (800) 275-3290. Phone: (469) 549-7100. Fax: (972) 906-1499. Web Site: www.overheaddoor.com. E-mail: sales@overheaddoor.com.
- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.

2.2 GLAZED ALUMINUM SECTIONAL OVERHEAD DOORS

- A. Glazed Sectional Overhead Doors: 521 Series Aluminum Doors by Overhead Door Corporation.
 - 1. Door Assembly: Stile and rail assembly secured with 1/4 inch (6 mm) diameter through rods.
 - a. Panel Thickness: 1-3/4 inches (44 mm).
 - b. Center Stile Width: 2-11/16 inches (68 mm)
 - c. End Stile Width: 3-5/16 inches (84 mm) - 2 Per End
 - d. Intermediate Rail Pair Width: 3-11/16 inches (94 mm).
 - e. Top Rail Width:
 - 1) 2-3/8 inches (60 mm).
 - 2) 3-3/4 inches (95 mm).
 - f. Bottom Rail Width:
 - 1) 3-3/4 inches (95 mm).
 - 2) 4-1/2 inches (114 mm).
 - g. Aluminum Panels: 0.050 inch (1.3 mm) thick, aluminum.
 - h. Stiles and Rails: 6063 - T6 aluminum.
 - i. Glazing:
 - 1) 1/8 inch (3 mm) Acrylic glazing.
 - 2) 1/4 inch (6 mm) Acrylic glazing.
 - 3) 1/8 inch (3 mm) Clear Lexan glazing.
 - 4) 1/4 inch (6 mm) Clear Lexan glazing.
 - 5) 1/2 inch (12.5 mm) Clear Lexan Insulated glazing.
 - 6) 1/8 inch (3 mm) Tempered glass.
 - 7) 1/4 inch (6 mm) Tempered glass.
 - 8) 1/2 inch (12.5 mm) Tempered Insulating glass.
 - 9) 1/4 inch (6 mm) Wire glass.
 - 10) 1/8 inch (3 mm) Double Strength glass.
 - 11) 1/2 inch (12.5 mm) Double Strength Insulating glass.
 - 12) 1/8 inch (3 mm) Low E glazing.
 - 13) 1/4 inch (6 mm) Low E glazing.
 - 14) 1/2 inch (12.5 mm) Low E Insulated glazing.
 - 15) 1/8 inch (3 mm) Solar Bronze glazing.
 - 16) 1/4 inch (6 mm) Solar Bronze glazing.
 - 17) 1/2 inch (12.5 mm) Solar Bronze Insulated glazing.
 - 18) 1/8 inch (3 mm) Obscure glazing.
 - 19) 1/4 inch (6 mm) Obscure glazing.
 - 20) 1/2 inch (12.5 mm) Obscure Insulated glazing.
 - 21) 1/4 inch (6 mm) Twin-Wall Polycarbonate (clear, bronze, white).
 - 22) 3/8 inch (9.5 mm) Twin-Wall Polycarbonate (clear, bronze, white).
 - 23) 5/8 inch (15.87 mm) Triple-Wall Polycarbonate (clear, bronze, white).
 - 2. Finish and Color:

- a. Anodized Finish: Clear anodized.
 - b. Anodized Finish: Bronze anodized.
 - c. Powder coat finish bronze light.
 - d. Powder coat finish bronze medium.
 - e. Powder coat finish bronze dark.
 - f. Powder Coating Finish: Color as selected by Architect from manufacturer's standard colors.
3. Windload Design: Provide to meet the Design/Performance requirements specified.
4. Hardware: Galvanized steel hinges and fixtures. Precision bearing rollers with hardened steel races.
5. Lock:
- a. None
 - b. Interior galvanized single unit with interlock.
6. Weatherstripping:
- a. Flexible bulb-type strip at bottom section.
 - b. Flexible Jamb seals.
 - c. Flexible Header seal.
7. Track: Provide track as recommended by manufacturer to suit loading required and clearances available.
8. Motor: Direct drive, integrated gear motor/brake assembly sized for openings. Provide with a manual hand chain for operation during power outages. Operator and drive assembly is provided with all wiring harnesses needed direct from the factory
- a. Entrapment Protection: Required for momentary contact or radio control operation.
 - 1) Wireless electric sensing edge monitored to meet UL 325/2010.
 - 2) Wired electric sensing edge monitored to meet UL 325/2010.
 - 3) Photoelectric sensors that cast an invisible beam across the door opening and reverses the downward motion of the door when an object enters the path of the beam.
 - 4) Built-in (to motor assembly) brake mechanism eliminates uncontrolled curtain travel independent of other safeties.
 - b. Operator Controls:
 - 1) Push-button operated control stations with open, close, and stop buttons.
 - 2) Key operated control stations with open, close, and stop buttons.
 - 3) Push-button and key operated control stations with open, close, and stop buttons.
 - 4) Flush mounting.
 - 5) Surface mounting.
 - 6) Interior location.
 - 7) Exterior location.
 - 8) Both interior and exterior location.
 - 9) One Open/Close/Stop push button station incorporated into Control Panel.
 - 10) Radio control.
 - 11) Loop detectors
 - 12) Motion detectors.
 - c. Special Operation:
 - 1) Pull switch.
 - 2) Vehicle detector operation.
 - 3) Radio control operation.
 - 4) Card reader control.
 - 5) Photocell operation.
 - 6) Door timer operation.
 - 7) Commercial light package.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until openings have been properly prepared.
- B. Verify wall openings are ready to receive work and opening dimensions and tolerances are within specified limits.
- C. Verify electric power is available and of correct characteristics.
- D. If preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install overhead doors and track in accordance with approved shop drawings and the manufacturer's printed instructions.
- B. Coordinate installation with adjacent work to ensure proper clearances and allow for maintenance.
- C. Anchor assembly to wall construction and building framing without distortion or stress.
- D. Securely brace door tracks suspended from structure. Secure tracks to structural members only.
- E. Fit and align door assembly including hardware.
- F. Coordinate installation of electrical service. Complete power and control wiring from disconnect to unit components.

3.4 CLEANING AND ADJUSTING

- A. Adjust door assembly to smooth operation and in full contact with weatherstripping.
- B. Clean doors, frames and glass.
- C. Remove temporary labels and visible markings.

3.5 PROTECTION

- A. Do not permit construction traffic through overhead door openings after adjustment and cleaning.
- B. Protect installed products until completion of project.

- C. Touch-up, damaged coatings and finishes and repair minor damage before Substantial Completion.

END OF SECTION