

SX/HX Control Board Cover Installation

WARNING

BE SURE ELECTRICAL POWER HAS BEEN DISCONNECTED FROM THE INPUT POWER LINES PRIOR TO REMOVING THE ELECTRICAL BOX COVER. AN APPROPRIATE LOCKOUT/TAGOUT PROCEDURE IS RECOMMENDED

1. Remove power from unit. Use proper lockout/tagout procedures (reference OSHA standard 1910.147).
2. Remove the electrical box cover.
3. Remove the hinge and screw, and set them aside.
4. Remove the latch and screw, and set them aside.
5. Install the control board cover. Line it up with the holes in the electrical box.
6. Re-attach the hinge. Fasten the screw to the electrical box and the control board cover.
7. Re-attach the latch. Fasten the screw to the electrical box and the control board cover.
8. Install the remaining screw as shown below to the electrical box and the control board cover.
9. Add Hazardous Voltage label.
10. Re-install electrical box cover.
11. Return power to operator.

